



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

April 10, 2008

Mr. Gerardo Rios
Chief, Permits Office
U.S. EPA – Region IX – Air 3
75 Hawthorne St.
San Francisco, CA 94105

**Subject: Title V Permit to Operate Revision
University of California, Irvine – ID # 800288**

Dear Mr. Rios:

The University of California, Irvine has revised their Title V Facility Permit by adding emergency internal combustion engine A/N 475432 and removing engine A/N 313341. This revision is considered a “de minimis significant permit revision” to their Title V Facility Permit and a copy was sent for your review on February 7, 2008.

Please insert the enclosed sections into the facility permit and discard the earlier versions. Questions concerning these changes should be directed to the processing engineer, Maria Vibal, at (909) 396-2422.

Sincerely,

Michael D. Mills

Michael D. Mills, P.E.
Senior Manager
General Commercial and Energy Team
Engineering and Compliance

MDM:RGC:MV

Enclosures

cc: (w/o) Enclosures
Title V Facility File
Title V Admin File

Certified Mail
Return Receipt Requested



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	0	03/26/2001
B	RECLAIM Annual Emission Allocation	0	03/26/2001
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	10	04/10/2008
E	Administrative Conditions	0	03/26/2001
F	RECLAIM Monitoring and Source Testing Requirements	0	03/26/2001
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	0	03/26/2001
H	Permit To Construct and Temporary Permit to Operate	0	03/26/2001
I	Compliance Plans & Schedules	0	03/26/2001
J	Air Toxics	0	03/26/2001
K	Title V Administration	10	04/10/2008
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	0	03/26/2001
B	Rule Emission Limits	4	04/10/2008



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

**Facility Equipment and Requirements
(Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application Number	Permit Number	Equipment Description
225130	D25027	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
225132	D25028	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
225134	D25029	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
225140	D63551	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
225155	D25038	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
225156	D25039	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
225157	D25040	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
225159	D25042	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
225164	D25044	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
227764	D25804	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
227765	D36514	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
243646	D49623	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
289120	D85898	IC ENGINE (51-500 HP) NON-EMERGENCY PORTABLE - DIESEL
290247	D81029	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
294680	D86304	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
310432	D95768	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

311658	D96544	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
312267	D96851	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
312562	D97129	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
313139	D98870	IC ENGINE (51-500 HP) EMERGENCY FIRE PUMP DRIVER - DIESEL
318209	F4492	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
324009	F5195	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
327619	F7047	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
366211	F35694	BOILER (20-50 MMBTU/HR) NATURAL GAS OR OIL FIRED
366212	F35695	BOILER (20-50 MMBTU/HR) NATURAL GAS OR OIL FIRED
366213	F35696	BOILER (20-50 MMBTU/HR) NATURAL GAS ONLY
366214	F35697	BOILER (20-50 MMBTU/HR) NATURAL GAS ONLY
366228	F25554	SCRUBBER, OTHER VENTING M.S.
366230	F25555	SCRUBBER, OTHER VENTING M.S.
374650	F35061	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
374651	F41560	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
384780	F41561	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
386969	F41563	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
393262	F47038	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
393963	F47962	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
396763	F48776	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
404942	F57961	PAINT SPRAY BOOTH
407243	F55884	IC ENGINE (51-500 HP) EMERGENCY ELEC



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

		GEN – NATURAL GAS
407769	F55887	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
409168	F57692	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
422431	F64985	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
433329	N15037	GASOLINE STORAGE & DISPENSING EQUIPMENT
443567	F87183	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
443783	F87144	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
448109	F87145	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
447332	PERMIT TO CONSTRUCT	SELECTIVE CATALYTIC REDUCTION
447333	PERMIT TO CONSTRUCT	TURBINE ENGINE (<= 50 MW) NAT GAS ONLY
449144	F78998	UNDERGROUND SOIL VAPOR EXTRACTION AND TREATMENT SYSTEM
463910	F90012	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
464442	F90013	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
475432	F96301	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]
2. THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPMV BY WEIGHT AS SUPPLIED BY THE SUPPLIER.
[RULE 431.2]
3. THE OPERATOR SHALL NOT USE NATURAL GAS CONTAINING SULFUR COMPOUNDS, CALCULATED AS H₂S, IN EXCESS OF 16 PPMV. THE OPERATOR SHALL NOT USE OR SELL GASEOUS FUEL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 40 PPMV CALCULATED AS HYDROGEN SULFIDE AVERAGED OVER FOUR HOURS.
[RULE 431.1]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D25027
A/N 225130**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL FUELED, EMERGENCY, MODEL NO. 3208, SERIAL NO. 29A01590, 8 CYLINDERS, FOUR CYCLE, NATURALLY ASPIRATED, 156 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

6. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D25028
A/N 225132**

Equipment Description:

INTERNAL COMBUSTION ENGINE, MITSUBISHI, DIESEL FUELED, EMERGENCY, MODEL NO. 6D16T, SERIAL NO. 6D16388999, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED, 184 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

6. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D25029
A/N 225134**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY, MODEL NO. DT-855-PG335, SERIAL NO. 671135, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED, 335 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

6. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D63551
A/N 225140**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CONTINENTAL, MODEL NO. HD277, SERIAL NO. 8298, EMERGENCY ELECTRICAL GENERATION, DIESEL-FUELED, 4 CYLINDERS, FOUR CYCLE, NATURALLY ASPIRATED, 75 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. EXCEPT FOR MAINTENANCE TESTING PURPOSES, THIS ENGINE SHALL ONLY OPERATE DURING UTILITY FAILURE PERIODS.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS EQUIPMENT SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATING RECORD OF THE EQUIPMENT SHALL BE MAINTAINED IN A FORMAT APPROVED BY THE DISTRICT, FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST BY DISTRICT PERSONNEL. THE RECORD SHALL INCLUDE, AT A MINIMUM, THE DAYS AND HOURS OF OPERATION AND THE AMOUNT OF FUEL USED.
[RULE 1303 (b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

7. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765

Section D	Page 10
Facility I.D.#	800288
Revision #:	10
Date:	April 10, 2008

FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D25038
A/N 225155**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY, MODEL NO. H672BG160, SERIAL NO. 601009, 6 CYLINDERS, FOUR CYCLE, NATURALLY ASPIRATED, 160 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

6. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

**Permit No. D25039
A/N 225156**

Equipment Description:

INTERNAL COMBUSTION ENGINE, HERCULES, DIESEL FUELED, EMERGENCY, MODEL NO. D3000T, SERIAL NO. HB3412256, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED 120 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

6. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D25040
A/N 225157**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY, MODEL NO. H73P160, SERIAL NO. 32037, 6 CYLINDERS, FOUR CYCLE, NATURALLY ASPIRATED, 160 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

6. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D25042
A/N 225159**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY, PORTABLE, MODEL NO. NT-855-G SERIAL NO. 10617058, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED 335 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

6. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D25044
A/N 225164**

Equipment Description:

INTERNAL COMBUSTION ENGINE, KOMATSU LTD FOCONAN, DIESEL FUELED, EMERGENCY, MODEL NO. 671T, SERIAL NO. 53544, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED 160 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

6. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

**Permit No. D25804
A/N 227764**

Equipment Description:

INTERNAL COMBUSTION ENGINE, KOHLER, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 100ROZJ, TURBOCHARGED, 6 CYLINDERS, FOUR CYCLE, 166 BHP, WITH 1 EXHAUST.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. AN ELAPSED TIMER SHALL BE INSTALLED/MAINTAINED, SO AS TO INDICATE IN CUMULATIVE HOURS, THE AMOUNT OF TIME THE ENGINE HAS OPERATED.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 125 HOURS (CUMULATIVE) IN ANY ONE YEAR UNLESS ADDITIONAL HOURS ARE OTHERWISE AUTHORIZED BY THE EXECUTIVE OFFICER. THIS EQUIPMENT MAY ONLY OPERATE DURING MAINTENANCE TESTING, PERFORMANCE TESTING, OR IN CASES OF EMERGENCY.
[RULE 1304(a)-MODELING AND OFFSET]
5. THE UNCONTROLLED EMISSION RATE OF REACTIVE ORGANIC GASES SHALL NOT EXCEED 0.19 LB/HR; THE UNCONTROLLED EMISSION RATE OF OXIDES OF NITROGEN SHALL NOT EXCEED 4.22 LB/HR.
[RULE 1304(a)-MODELING AND OFFSET]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
7. THE IGNITION TIMING OF THIS ENGINE MUST BE INSPECTED, ADJUSTED, CERTIFIED, AT A MINIMUM, ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND ACCORDING TO THE ENGINE MANUFACTURER'S PROCEDURES.
[RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

8. AN OPERATING RECORD OF THIS EQUIPMENT MUST BE MAINTAINED IN A FORMAT APPROVED IN WRITING BY THE DIRECTOR OF ENFORCEMENT. THE RECORD MUST INCLUDE, AT A MINIMUM, THE HOURS AND DAYS OF OPERATION AND THE QUANTITY OF FUEL USED. THE OPERATING RECORD MUST BE KEPT FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
9. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D36514
A/N 227765**

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 8V-92TTA-400ROZD, TURBOCHARGED, AFTERCOOLED 8 CYLINDERS, 643 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED, SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 152 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. A DAILY LOG LISTING THE ENGINE OPERATING TIME, IN HOURS, SHALL BE MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. EXCEPT FOR MAINTENANCE TESTING PURPOSES, THIS ENGINE SHALL ONLY OPERATE DURING UTILITY FAILURE PERIODS.
[RULE 1304(a)-MODELING AND OFFSET]
7. OPERATION OF THIS ENGINE FOR MAINTENANCE TESTING SHALL NOT EXCEED 1 HOUR A WEEK.
[RULE 1304(a)-MODELING AND OFFSET]
8. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
9. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



~~FACILITY PERMIT TO OPERATE~~
UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

Permit No. D49623
A/N 243646

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6CTA8.3-G, TURBOCHARGED, AFTERCOOLED 6 CYLINDERS, FOUR CYCLES, 277 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THIS OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D85898
A/N 289120**

Equipment Description:

INTERNAL COMBUSTION ENGINE, PORTABLE, JOHN DEERE, MODEL NO. 4039TF, SERIAL NO. T04039T408110, DIESEL FUELED, 4 CYLINDERS, TURBOCHARGED, 110 BHP, DRIVING A BRUSH CHIPPER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 12 CONSECUTIVE MONTHS AT ANY ONE LOCATION IN THE SOUTH COAST AQMD.
[RULE 1110.2]
4. THE TOTAL OPERATING TIME OF THIS ENGINE IN THE SOUTH COAST AQMD SHALL NOT EXCEED 120 HOURS IN ANY ONE CALENDAR MONTH.
[RULE 1110.2, RULE 1303(b)(2)-OFFSET]
5. THIS ENGINE SHALL NOT OPERATE ON THE SAME SITE SIMULTANEOUSLY OR ON THE SAME DAY WITH ANY OTHER PORTABLE ENGINE WHICH IS OWNED OR OPERATED BY THE SAME PERSON OR PERSONS UNDER COMMON CONTROL UNLESS THE EMISSIONS FROM THE OTHER ENGINE ARE EITHER EXEMPT FROM REGULATION XIII OR OFFSET WITH EMISSION REDUCTION CREDITS.
[RULE 1303(b)(2)-OFFSET]
6. A TIMER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2]
7. AN OPERATING LOG OF THIS ENGINE SHALL BE MAINTAINED FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST BY DISTRICT PERSONNEL. THE LOG SHALL INCLUDE, AT A MINIMUM, THE DATE, THE ELAPSED TIME, IN HOURS, AND THE LOCATION OF OPERATION.
[RULE 1110.2]
8. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1110.2, RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

Permit No. D81029
A/N 290247

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, 6 CYLINDERS TURBOCHARGED, AFTERCOOLED, MODEL NO. NTA855-G2, 465 BHP DIESEL FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. OPERATION OF THIS ENGINE FOR MAINTENANCE TESTING SHALL NOT EXCEED 0.5 HOUR A WEEK.
[RULE 1304(a)-MODELING AND OFFSET]
5. THE OPERATING TIME OF THE ENGINE SHALL NOT EXCEED 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
6. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D86304
A/N 294680**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3306B, SERIAL NO. 85209605, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, 306 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED, SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D95768
A/N 310432**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL NO. NTA855G3, 535 BHP, 6 CYLINDERS, DIESEL FIRED, TURBOCHARGED/AFTERCOOLED, EMERGENCY ELECTRIC GENERATION.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED, SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

Permit No. D96544
A/N 311658

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL NO. LTA10-G1, SERIAL NO. K940560530, 6 CYLINDERS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, TURBOCHARGED AND AFTERCOOLED, 380 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED, SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D96851
A/N 312267**

Equipment Description:

INTERNAL COMBUSTION ENGINE, JOHN DEERE, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL NO. 6076A (224 KW), 300 BHP, DIESEL FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

Permit No. D97129
A/N 312562

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT, DIESEL FUELED, 16 CYLINDERS, TURBOCHARGED AFTERCOOLED, MODEL NO. 16V-92TA, SERIAL NO. 81637416, 1095 BHP, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED, SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 98 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. D98870
A/N 313139**

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL DDFP-L3DT, 160 BHP, 3 CYLINDERS, DIESEL FIRED, TURBOCHARGED, EMERGENCY FIRE PUMP DRIVER.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F4492
A/N 318209**

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL NO. 8V92TA, 643 BHP, 8 CYLINDER, DIESEL FUELED, TURBOCHARGED, AFTERCOOLED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F5195
A/N 324009**

Equipment Description:

INTERNAL COMBUSTION ENGINE, NAVISTAR INTERNATIONAL, 6 CYLINDERS, TURBOCHARGED,
MODEL NO. S-408.7LT, 205 BHP, DIESEL FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED, UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE UNIV. CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

**Permit No. F7047
A/N 327619**

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, 12 CYLINDER, DIESEL FUELED, TURBOCHARGED, AFTERCOOLED, MODEL NO. 8123-7416 (12V-92TA), SERIAL NO. 383150, 947 BHP DIESEL FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 111 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS AND THE REASON FOR THE OPERATION SHALL BE KEPT AND ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE UPON REQUEST OF DISTRICT PERSONNEL.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 1.7 DEGREES RETARDED RELATIVE TO PRODUCTION TIMING AS ESTABLISHED BY DETROIT DIESEL IN PRODUCT ANNOUNCEMENT INJECTION TIMING RETARD INSTRUCTION FOR CONFORMANCE WITH THE SCAQMD'S GENERAL PERMIT REGISTRATION PROGRAM 12 V92TA GENERATOR SET ENGINE MODEL 8123-7416.
[RULE 1303(a)(1)-BACT]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F35694
A/N 366211**

Equipment Description:

BOILER NO.1, BABCOCK & WILCOX, MODEL NO. 21800, RATED AT 34,125,000 BTU/HR., NATURAL GAS OR OIL-FIRED, WITH ONE FORNEY LOW NO_x BURNER, WITH A FLUE GAS RECIRCULATION SYSTEM AND OXYGEN TRIM, AND WITH AMBER 363 SECONDARY FUEL.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY, EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT OR TESTING, WHEN AMBER 363 FUEL IS PERMITTED TO BE FIRED.
[RULE 1303(b)(2)-OFFSET]
4. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
5. WHEN OPERATING ON NATURAL GAS, THIS BOILER SHALL EMIT NO MORE THAN 20 PPM OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂. WHEN OPERATING ON AMBER 363, THIS BOILER SHALL EMIT NO MORE THAN 40 PPM OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1303(b)(2)-OFFSET]



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

7. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 6 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET]

Periodic Monitoring:

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NO_x EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004(a)(4)]
9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004(a)(4)]
10. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF AMBER 363 FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

**D. VISIBLE EMISSION OBSERVATION RECORD BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]**

11. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 5.2. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

12. FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

NOx: 30 PPMV, RULE 1146
NOx: 20 PPMV, RULE 1303(b)(2)-OFFSET
NOx: 40 PPMV, RULE 1146
CO: 400 PPMV, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F35695
A/N 366212**

Equipment Description:

BOILER NO.2, BABCOCK & WILCOX, MODEL NO. 21800, RATED AT 34,125,000 BTU/HR., NATURAL GAS OR OIL-FIRED, WITH ONE FORNEY LOW NO_x BURNER, WITH A FLUE GAS RECIRCULATION SYSTEM AND OXYGEN TRIM, AND WITH AMBER 363 SECONDARY FUEL.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY, EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT OR TESTING, WHEN AMBER 363 FUEL IS PERMITTED TO BE FIRED.
[RULE 1303(b)(2)-OFFSET]
4. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
5. WHEN OPERATING ON NATURAL GAS, THIS BOILER SHALL EMIT NO MORE THAN 20 PPM OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂. WHEN OPERATING ON AMBER 363, THIS BOILER SHALL EMIT NO MORE THAN 40 PPM OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1303(b)(2)-OFFSET]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

7. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 6 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET]

Periodic Monitoring:

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NO_x EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004(a)(4)]
9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004(a)(4)]
10. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF AMBER 363 FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND

D. VISIBLE EMISSION OBSERVATION RECORD BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

11. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 5.2. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

12. FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

NOx: 30 PPMV, RULE 1146
NOx: 20 PPMV, RULE 1303(b)(2)-OFFSET
NOx: 40 PPMV, RULE 1146
CO: 400 PPMV, RULE 1146
CO: 2000 PPMV, RULE 407



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765

Section D	Page 39
Facility I.D.#	800288
Revision #:	10
Date:	April 10, 2008

**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PM: 0.1 GR/SCF, RULE 409



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F35696
A/N 366213**

Equipment Description:

BOILER NO.3, NEBRASKA, MODEL NO. 201495, RATED AT 36,225,000 BTU/HR., NATURAL GAS-FIRED, WITH ONE FORNEY LOW NO_x BURNER, FLUE GAS RECIRCULATION SYSTEM AND OXYGEN TRIM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1303(b)(2)-OFFSET]
4. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
5. THIS BOILER SHALL EMIT NO MORE THAN 20 PPM OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
7. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 6 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET]

Periodic Monitoring:



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NO_x EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT. [RULE 3004(a)(4)]
9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT. [RULE 3004(a)(4)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

NO_x: 30 PPMV, RULE 1146
NO_x: 20 PPMV, RULE 1303(b)(2)-OFFSET
CO: 400 PPMV, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

**Permit No. F35697
A/N 366214**

Equipment Description:

BOILER NO.4, TRANE-MURRAY, MODEL NO. MCF-2-38, RATED AT 39,000,000 BTU/HR., NATURAL GAS-FIRED, WITH ONE FORNEY LOW NO_x BURNER, FLUE GAS RECIRCULATION SYSTEM AND OXYGEN TRIM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1303(b)(2)-OFFSET]
4. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
5. THIS BOILER SHALL EMIT NO MORE THAN 20 PPM OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1303(b)(2)-OFFSET]
7. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 6 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET]

Periodic Monitoring:



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NO_x EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004(a)(4)]
9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ANNUALLY USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004(a)(4)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

NO_x: 30 PPMV, RULE 1146
NO_x: 20 PPMV, RULE 1303(b)(2)-OFFSET
CO: 400 PPMV, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F25554
A/N 366228**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM, NO. 2, CONTROLLED DECOMPOSITION/OXIDATION SYSTEM
DELATECH, MODEL 855 V-M, SERIAL NO. 800640 CONSISTING OF:

1. THERMAL REACTION SECTION, 2'W X 2'L X 4'-6" H.
2. PRIMARY COOLING/SCRUBBING SECTION.
3. EXHAUST SYSTEM (MAXIMUM FLOW RATE, 75 SCFM), VENTING THREE RIE REACTORS (RULE 219 EXEMPT EQUIPMENT).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A FLOW METER SHALL BE INSTALLED AND MAINTAINED ON THE SCRUBBING SOLUTION RECIRCULATION IN THE FRESH WATER FEED LINE TO THE PRIMARY COOLING SECTION.
[RULE 1303(a)(1)-BACT]
4. NOT LESS THAN 2.5 GPM OF FRESH WATER SHALL BE SUPPLIED TO THE PRIMARY COOLING SECTION WHEN THE EQUIPMENT IT SERVES IS IN OPERATION.
[RULE 1303(a)(1)-BACT]
5. THIS EQUIPMENT SHALL NOT BE OPERATED BELOW 1500 DEGREES F.
[RULE 1303(a)(1)-BACT]
6. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULE 1401 AS AMENDED AUGUST 13, 1999.
[RULE 1401]
7. THIS EQUIPMENT SHALL BE OPERATED WHENEVER THE BASIC EQUIPMENT IT SERVES IS/ARE IN OPERATION.
[RULE 1303(a)(1)-BACT]

Periodic Monitoring:



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

8. THE OPERATOR SHALL DETERMINE AND RECORD THE FLOW RATE OF THE SCRUBBING SOLUTION ONCE EVERY DAY.
[RULE 3004 (a)(4)]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

**Permit No. F25555
A/N 366230**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM, NO. 1, CONTROLLED DECOMPOSITION/OXIDATION SYSTEM
DELATECH, MODEL 855 V-M, SERIAL NO. 800642 CONSISTING OF:

1. THERMAL REACTION SECTION, 2'W X 2'L X 4'-6" H.
2. PRIMARY COOLING/SCRUBBING SECTION.
3. EXHAUST SYSTEM (MAXIMUM FLOW RATE, 75 SCFM), VENTING TWO LPCVD REACTORS (RULE 219 EXEMPT EQUIPMENT).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A FLOW METER SHALL BE INSTALLED AND MAINTAINED ON THE SCRUBBING SOLUTION RECIRCULATION IN THE FRESH WATER FEED LINE TO THE PRIMARY COOLING SECTION.
[RULE 1303(a)(1)-BACT]
4. NOT LESS THAN 2.5 GPM OF FRESH WATER SHALL BE SUPPLIED TO THE PRIMARY COOLING SECTION WHEN THE EQUIPMENT IT SERVES IS IN OPERATION.
[RULE 1303(a)(1)-BACT]
5. THIS EQUIPMENT SHALL NOT BE OPERATED BELOW 1500 DEGREES F.
[RULE 1303(a)(1)-BACT]
6. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULE 1401 AS AMENDED AUGUST 13, 1999.
[RULE 1401]
7. THIS EQUIPMENT SHALL BE OPERATED WHENEVER THE BASIC EQUIPMENT IT SERVES IS/ARE IN OPERATION.
[RULE 1303(a)(1)-BACT]

Periodic Monitoring:



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

8. THE OPERATOR SHALL DETERMINE AND RECORD THE FLOW RATE OF THE SCRUBBING SOLUTION ONCE EVERY DAY.
[RULE 3004 (a)(4)]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F35061
A/N 374650**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3406DITA, SERIAL NO. 42R05103, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, FOUR CYCLE, 587 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F41560
A/N 374651**

Equipment Description:

(LOCATED AT EAST CAMPUS RECREATION CENTER)

INTERNAL COMBUSTION ENGINE, GENERAC, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 50DT, SERIAL NO. 2045946 (GENERATOR), TURBOCHARGED, FOUR CYLINDERS, 122 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR. THIS EQUIPMENT SHALL BE TURNED ON ONLY TO PROVIDE EXIT LIGHTING FOR THE EAST CAMPUS RECREATION CENTER.
[RULE 1304(a)-MODELING AND OFFSET]
7. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 3 1/2 HOURS A DAY IN THE EVENT OF EMERGENCIES SPECIFIED IN CONDITION NO. 6.
[RULE 1303(a)(1)-BACT]



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

8. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
9. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

**Permit No. F41561
A/N 384780**

Equipment Description:

(LOCATED AT IRVINE HALL-WEST)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 4BT3.9-G4, SERIAL NO. 45788098, TURBOCHARGED, FOUR CYLINDERS, FOUR CYCLE, 102 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.
[RULE 1304(a)-MODELING AND OFFSET]
7. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F41563
A/N 386969**

Equipment Description:

(LOCATED AT BECKMAN LASER INST. BLDG. #24)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6CT8.3-G2, SERIAL NO. 45675235, TURBOCHARGED, SIX CYLINDERS, FOUR CYCLE, 207 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.
[RULE 1304(a)-MODELING AND OFFSET]
7. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

**Permit No. F47038
A/N 393262**

Equipment Description:

(LOCATED AT 4302 CAMPUS DR.)

INTERNAL COMBUSTION ENGINE, PERKINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. NAVISTAR GB230, TURBOCHARGED, SIX CYLINDERS, FOUR CYCLE, 230 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.
[RULE 1304(a)-MODELING AND OFFSET]
7. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F47962
A/N 393963**

Equipment Description:

(LOCATED AT NATURAL SCIENCES UNIT I)

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. R123-7K35, SERIAL NO. 5352001950, TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, FOUR CYCLE, 910 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.
[RULE 1304(a)-MODELING AND OFFSET]
7. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F48776
A/N 396763**

Equipment Description:

(LOCATED AT SPRAGUE HALL)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3412DTTA/500KW, TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, FOUR CYCLE, 1372 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.
[RULE 1304(a)-MODELING AND OFFSET]
7. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

Permit No. F57961
A/N 404942

Equipment Description:

(located at the Facility Services)

SPRAY BOOTH, DEVILBISS, MODEL NO. 6002, FLOOR TYPE, 8'-0" W. X 6'-0" L. X 7'-0" H., WITH FIFTEEN 20" X 25" EXHAUST FILTERS, AND ONE 1 HP EXHAUST FAN.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
3. THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS ALL EXHAUST AIR PASSES THROUGH FILTER MEDIA AT LEAST TWO INCHES THICK.
[RULE 1303(a)(1)-BACT]
4. A GAUGE SHALL BE INSTALLED AND MAINTAINED TO INDICATE, IN INCHES OF WATER, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE EXHAUST FILTERS. IN OPERATION, THE PRESSURE DIFFERENTIAL SHALL NOT EXCEED 0.25 INCH OF WATER.
[RULE 1303(a)(1)-BACT]
5. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 1136 AND 1171.
[RULE 1136, RULE 1171]
6. THE TOTAL QUANTITY OF COATINGS AND SOLVENTS USED IN THIS EQUIPMENT SHALL NOT BE MORE THAN THREE GALLONS IN ANY ONE DAY.
[RULE 1303(b)(2)-OFFSET]
7. MATERIALS USED IN THIS EQUIPMENT SHALL NOT CONTAIN ANY CARCINOGENIC AIR CONTAMINANTS AS IDENTIFIED IN RULE 1401 AS AMENDED MAY 3, 2002.
[RULE 1401]
8. MATERIAL SAFETY DATA SHEETS FOR ALL MATERIALS USED IN THIS EQUIPMENT SHALL BE KEPT CURRENT AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 109, RULE 1136, RULE 1171]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

9. THE OPERATOR SHALL COMPLY WITH RULE 109 (RECORD KEEPING FOR VOLATILE ORGANIC COMPOUNDS EMISSIONS).
[RULE 109]
10. ALL RECORDS SHALL BE RETAINED AT THE FACILITY FOR A MINIMUM OF FIVE YEARS, AND SHALL BE MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 109]

Periodic Monitoring:

11. THE OPERATOR SHALL PERFORM A WEEKLY INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.
[RULE 3004 (a)(4)]
12. THE OPERATOR SHALL DETERMINE AND RECORD THE PRESSURE DROP ACROSS THE FILTER MEDIA ONCE EVERY WEEK.
[RULE 3004 (a)(4)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1136, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
UNIV. CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F55884
A/N 407243**

Equipment Description:

(located at the Administration Building)

INTERNAL COMBUSTION ENGINE, FORD, NATURAL GAS-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. CSG-6491-6005-A, SERIAL NO. 69064-1-04-00, NATURALLY ASPIRATED, SIX CYLINDERS, FOUR CYCLE, 82 BHP, EQUIPPED WITH A THREE-WAY NON-SELECTIVE CATALYTIC REDUCTION CONVERTER, JOHNSON MATTHEY, MODEL NO. BANDITO CX 4-4.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.
[RULE 1304(a)-MODELING AND OFFSET]
7. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1304(a)-MODELING AND OFFSET]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

8. THE CATALYTIC CONVERTER TEMPERATURE AND EXHAUST OXYGEN CONCENTRATION SHALL BE MAINTAINED WITHIN THE EFFECTIVE OPERATING RANGE OF THE CATALYTIC CONVERTER AS SPECIFIED BY THE MANUFACTURER.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1303(a)(1)-BACT]

9. THE ENGINE EMISSIONS SHALL NOT EXCEED THE FOLLOWING LIMITS :

VOLATILE ORGANIC COMPOUNDS (VOC)	1.5 GRAMS/BHP-HR
NITROGEN OXIDES	1.5 GRAMS/BHP-HR
CARBON MONOXIDE	2.0 GRAMS/BHP-HR

[RULE 1303(a)(1)-BACT]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2.0 GRAMS/BHP-HR, RULE 1303(a)(1)-BACT
NOx: 1.5 GRAMS/BHP-HR, RULE 1303(a)(1)-BACT
VOC: 1.5 GRAMS/BHP-HR, RULE 1303(a)(1)-BACT
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F55887
A/N 407769**

Equipment Description:

(located at Hewitt Hall)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3456 DITA AA, SERIAL NO. CBX00372, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, FOUR CYCLE, 764 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.
[RULE 1304(a)-MODELING AND OFFSET]
7. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F57692
A/N 409168**

Equipment Description:

(located at Natural Sciences – Unit 2)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. KTA50-G9, SERIAL NO. 25277466, TURBOCHARGED, AFTERCOOLED, 16 CYLINDERS, 2220 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 1304(a)-MODELING AND OFFSET]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
5. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. IN ADDITION TO MAINTENANCE AND PERFORMANCE TESTING, THIS ENGINE SHALL ONLY BE OPERATED DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING ANY STAGE II OR III ELECTRICAL EMERGENCY DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.
[RULE 1304(a)-MODELING AND OFFSET]
7. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F64985
A/N 422431**

Equipment Description:

(located at CAL-IT2)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3412DITTA, TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, FOUR CYCLE, 896 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. THE OPERATION OF THIS ENGINE BEYOND 50 HOURS PER YEAR FOR MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304(a)-MODELING AND OFFSET]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION OF THIS ENGINE. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303(b)(2)-OFFSET, RULE 1470]

7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

Permit No. N15037
A/N 433329

Equipment Description:

FUEL STORAGE AND DISPENSING FACILITY (LOCATED AT NORTH CAMPUS CORPORATION YARD, FLEET SERVICES) CONSISTING OF.

1. 1-DUAL COMPARTMENT ABOVEGROUND GASOLINE/DIESEL STORAGE TANK, SUPERVAULT TYPE (G-70-132-B), CYLINDRICAL, STANDING HORIZONTALLY, 20'-5" L X 11' 1" DIA., CAPACITY - 10000 GALLONS, CONCRETE INSULATION, EQUIPPED WITH A PRESSURE/VACUUM RELIEF VALVE, AND A SUBMERGED FILL TUBE, CONSISTING OF:
 - A. ONE 7000 GALLON GASOLINE COMPARTMENT TANK, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM.
 - B. ONE 3000 GALLON DIESEL COMPARTMENT TANK, NOT EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM.
2. 1-GASOLINE NOZZLE DISPENSING 1 PRODUCT ON A TANK TOP MOUNTED DISPENSER, EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM, BALANCE RETRACTOR (G-70-52-AM).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT WAS ISSUED, UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS.
[RULE 461]
4. EXCEPT FOR DIESEL TRANSFERS, PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461.
[RULE 461]
5. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS.
[RULE 461, RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

6. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE SYSTEM INCLUDING NOZZLE, VAPOR HOSE, SWIVELS, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURES DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED:

NITROGEN FLOWRATES (CFH)	DYNAMIC BACK PRESSURE (INCHES OF WATER)
60	0.35
80	0.62

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.4; METHODOLOGY 1. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN FORTY-EIGHT (48) HOURS OF TESTS.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE DYNAMIC BACK PRESSURE TESTS.
[RULE 461]

7. A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.3. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN FORTY-EIGHT (48) HOURS OF TEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE STATIC PRESSURE LEAK DECAY TEST.
[RULE 461]

8. IF THE CARB EXECUTIVE ORDER REQUIRES THE INSTALLATION OF A LIQUID REMOVAL DEVICE, A LIQUID REMOVAL RATE TEST SHALL BE CONDUCTED TO DEMONSTRATE THE REMOVAL OF GASOLINE FROM THE VAPOR PASSAGE OF THE COAXIAL HOSE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.6. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN FORTY-EIGHT (48) HOURS OF TEST.

THE SCAQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE LIQUID REMOVAL RATE TEST.



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

[RULE 461]

9. THE TESTING FREQUENCY FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT.

[RULE 461]

10. ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

[RULE 461]

11. THE MAXIMUM QUANTITY OF GASOLINE DISPENSED FROM THE STORAGE TANKS AT THIS FACILITY SHALL NOT EXCEED 12,000 GALLONS IN ANY ONE CALENDAR MONTH NOR 144,000 GALLONS IN ANY ONE CALENDAR YEAR.

[RULE 1303(b)(2)-OFFSET]

12. RECORDS OF MONTHLY AND ANNUAL FUEL DISPENSED SHALL BE PREPARED, SHALL BE RETAINED ON SITE FOR FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

[RULE 1303(b)(2)-OFFSET]

Periodic Monitoring:

13. THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(d)(5) CONDUCT A SEMI-ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND DISPENSING EQUIPMENT. THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT B, THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C, AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS. THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT.

[RULE 3004 (a)(4)]

Emissions And Requirements:

14. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

VOC: RULE 461

VOC: RULE 1170



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F87183
A/N 443567**

Equipment Description:

(located at the Medical Sciences I "C" Stack)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QST30-G1, TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, FOUR CYCLE, 1135 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

**Permit No. F87144
A/N 443783**

Equipment Description:

(located at Parking Structure #6/Campus Surge Building)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QSM11-G1, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, FOUR CYCLE, 395 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

- A. EMERGENCY USE HOURS OF OPERATION
- B. MAINTENANCE AND TESTING HOURS
- C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO OPERATE

Permit No. F87145
A/N 448109

Equipment Description:

(located at Berkeley Place – Adcom Building)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6BTAA5.9-G1, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, FOUR CYCLE, 208 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

- A. EMERGENCY USE HOURS OF OPERATION
- B. MAINTENANCE AND TESTING HOURS
- C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO CONSTRUCT

A/N 447332

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF :

1. REACTOR, ENGELHARD, SELECTIVE CATALYTIC REDUCTION, 15'-5" W. x 9'-5" H., WITH 278.3 CU. FT. OF DNX 930 TYPE CATALYST.
2. REACTOR, ENGELHARD, CARBON MONOXIDE OXIDATION CATALYST, 16'-11 1/2" W. x 11'-0" H., WITH 39 CU. FT. OF ADCAT CO CATALYST.
3. AMMONIA GENERATION AND INJECTION SYSTEM, HALDOR TOPSOE, UREA CONVERSION, FUEL TECH (ID).
4. UREA STORAGE TANK, 6000-GALLON CAPACITY.
5. CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS) AT THE OUTLET OF THE SCR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE IN OPERATION WHENEVER THE EQUIPMENT IT SERVES IS OPERATING, EXCEPT AS OTHERWISE NOTED IN THIS PERMIT.
[RULE 1303(a)(1)-BACT]
4. THE HOURLY AVERAGE AMMONIA CONCENTRATION AT THE EXIT OF THE SCR UNIT SHALL NOT EXCEED 5 PPMV CORRECTED TO 15 PERCENT OXYGEN WHEN THE SCR INLET TEMPERATURE EXCEEDS 500 DEGREES FAHRENHEIT.
[RULE 1303(a)(1)-BACT]
5. THE OPERATOR SHALL INSTALL AND MAINTAIN A TEMPERATURE GAUGE TO ACCURATELY INDICATE THE TEMPERATURE OF THE EXHAUST AT THE INLET TO THE SCR REACTOR. THE OPERATOR SHALL CONTINUOUSLY RECORD THE TEMPERATURE WITH A MEASURING DEVICE OR GAUGE ACCURATE TO +/- 5 PERCENT OF THE DEVICE FULL SPAN, CALIBRATED ONCE EVERY 12 MONTHS.
[RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

6. THE OPERATOR SHALL CONDUCT SOURCE TESTS FOR THE POLLUTANTS IDENTIFIED BELOW:

POLLUTANTS	REQUIRED TEST METHOD	AVERAGING TIME	TEST LOCATION
NH ₃	DISTRICT METHOD 5.3 AND 207.1 OR EPA METHOD 17	1 HOUR	OUTLET OF THE SCR

THE TEST SHALL BE CONDUCTED AND THE RESULTS SUBMITTED TO THE AQMD WITHIN 60 DAYS AFTER THE TEST DATE. THE AQMD SHALL BE NOTIFIED OF THE DATE AND TIME OF THE TEST AT LEAST 10 DAYS PRIOR TO THE TEST.

THE TEST SHALL BE CONDUCTED AT LEAST QUARTERLY DURING THE FIRST 12 MONTHS OF OPERATION OF THE SCR, AND AT LEAST ANNUALLY THEREAFTER. THE NO_x CONCENTRATION, AS DETERMINED BY THE CEMS, SHALL BE SIMULTANEOUSLY RECORDED DURING THE AMMONIA SLIP TEST. IF THE CEMS IS INOPERABLE, A TEST SHALL BE CONDUCTED TO DETERMINE THE NO_x EMISSIONS USING DISTRICT METHOD 100.1, MEASURED OVER A 60 MINUTE AVERAGING TIME PERIOD.

THE TEST SHALL BE CONDUCTED TO DEMONSTRATE COMPLIANCE WITH THE RULE 1303 CONCENTRATION LIMIT.
[RULE 1303(a)(1)-BACT]

7. THE SCR REACTOR SHALL BE OPERATED WITHIN THE TEMPERATURE RANGE OF 500-757 °F, EXCEPT DURING START-UP, SHUTDOWN AND INITIAL PLANT COMMISSIONING PERIODS.
[RULE 1303(a)(1)-BACT]
8. THE OPERATOR MAY, AT HIS DISCRETION, CHOOSE NOT TO USE AMMONIA INJECTION WHEN THE INLET EXHAUST TEMPERATURE TO THE SCR REACTOR IS 500 °F OR LESS, NOT TO EXCEED 3 HOURS DURING START-UPS WITHIN THE COMMISSIONING PERIOD AND 2 HOURS DURING START-UPS IN NORMAL OPERATION.
[RULE 1303(a)(1)-BACT]
9. ALL RECORDS REQUIRED BY THIS PERMIT SHALL BE RETAINED AT THE FACILITY FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST.
[RULE 1303(a)(1)-BACT]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NH₃: 5 PPMV, RULE 1303(a)(1)-BACT



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO CONSTRUCT

A/N 447333

Equipment Description:

COGENERATION SYSTEM CONSISTING OF :

1. GAS TURBINE, COMBINED CYCLE, SOLAR, MODEL NO. TITAN 130 T19501S, RATED AT 173,300,000 BTU/HR, NATURAL GAS-FIRED, DRIVING A 13.5-MW ELECTRICAL GENERATOR.
2. EXHAUST HEAT RECOVERY STEAM GENERATOR (HRSG), DELTAK, MODEL SPLIT CROSS-FLOW DINO, PRODUCING 122,000 LBS/HR OF SUPERHEATED STEAM.
3. DUCT BURNER, RATED AT 81,100,000 BTU/HR, NATURAL GAS-FIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1303(a)(1)-BACT, RULE 1303(b)(2)- OFFSET]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL SYSTEM WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO CONSTRUCT BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
5. THE EMISSIONS AT THE OUTLET OF THE CONTROL SYSTEM SHALL NOT EXCEED THE FOLLOWING LIMITS (AVERAGED OVER ANY ONE HOUR PERIOD):

COMPOUND	PPMV@15% O ₂ DRY
VOLATILE ORGANIC COMPOUNDS (VOC)	2
NITROGEN OXIDES	2
CARBON MONOXIDE	3
[RULE 1303(a)(1)-BACT]	

6. THE OPERATOR SHALL CONDUCT SOURCE TESTS FOR THE POLLUTANTS IDENTIFIED BELOW:



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

POLLUTANT	REQUIRED TEST METHOD	AVERAGING TIME	TEST LOCATION
CO	DISTRICT METHOD 100.1	1 HOUR	OUTLET OF THE SCR
NO _x	DISTRICT METHOD 100.1	1 HOUR	OUTLET OF THE SCR
PM	APPROVED DISTRICT METHOD	APPROVED DISTRICT TIME AVERAGE	OUTLET OF THE SCR
VOC	APPROVED DISTRICT METHOD	1 HOUR	OUTLET OF THE SCR
SOX	APPROVED DISTRICT METHOD	APPROVED DISTRICT TIME AVERAGE	FUEL SAMPLE
NH ₃	DISTRICT METHOD 5.3, 207.1 OR EPA METHOD 17	1 HOUR	OUTLET OF THE SCR

THE TEST SHALL BE CONDUCTED AFTER AQMD APPROVAL OF THE SOURCE TEST PROTOCOL, BUT NO LATER THAN 180 DAYS AFTER INITIAL START-UP OF THE TURBINE. THE AQMD SHALL BE NOTIFIED OF THE DATE AND TIME OF THE TEST AT LEAST 10 DAYS PRIOR TO THE TEST.

THE TEST SHALL BE CONDUCTED TO DETERMINE THE OXYGEN LEVELS IN THE EXHAUST. IN ADDITION, THE TEST SHALL RECORD THE FUEL FLOW RATE (CFH), THE FLUE GAS FLOW RATE, AND THE TURBINE GENERATING OUTPUT (MW).

THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH AN AQMD APPROVED SOURCE TEST PROTOCOL. THE PROTOCOL SHALL BE SUBMITTED TO THE AQMD ENGINEER NO LATER THAN 45 DAYS BEFORE THE PROPOSED TEST DATE AND SHALL BE APPROVED BY THE AQMD BEFORE TEST COMMENCES. THE TEST PROTOCOL SHALL INCLUDE THE PROPOSED OPERATING CONDITIONS OF THE TURBINE DURING THE TEST, THE IDENTITY OF THE TESTING LAB, A STATEMENT FROM THE TESTING LAB CERTIFYING THAT IT MEETS THE CRITERIA OF R-304, AND A DESCRIPTION OF ALL SAMPLING AND ANALYTICAL PROCEDURES.

THE TEST SHALL BE CONDUCTED WHEN THE COMBUSTION TURBINE GENERATOR AND DUCT BURNER ARE OPERATING AS CLOSE AS PRACTICABLE TO 100% LOAD, AND WHEN THE COMBUSTION TURBINE GENERATOR IS OPERATING AT 75% AND 50% OF MAXIMUM LOAD.
[RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

7. THE OPERATOR SHALL PROVIDE TO THE DISTRICT A SOURCE TEST REPORT IN ACCORDANCE WITH THE FOLLOWING SPECIFICATIONS:
 - A. SOURCE TEST RESULTS SHALL BE SUBMITTED TO THE DISTRICT NO LATER THAN 60 DAYS AFTER THE SOURCE TEST WAS COMPLETED.
 - B. EMISSION DATA SHALL BE EXPRESSED IN TERMS OF CONCENTRATION (PPMV), CORRECTED TO 15 PERCENT OXYGEN, DRY BASIS.



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

- C. ALL EXHAUST FLOW RATES SHALL BE EXPRESSED IN TERMS OF DRY STANDARD CUBIC FEET PER MINUTE (DSCFM) AND ACTUAL CUBIC FEET PER MINUTE (ACFM).
- D. ALL MOISTURE CONCENTRATIONS SHALL BE EXPRESSED IN TERMS OF PERCENTAGE BY VOLUME.
- E. EMISSION DATA SHALL BE EXPRESSED IN TERMS OF MASS RATE (LBS/HR). IN ADDITION, SOLID PM EMISSIONS, IF REQUIRED TO BE TESTED, SHALL ALSO BE REPORTED IN TERMS OF GRAINS PER DSCF.
- F. EMISSION DATA SHALL BE EXPRESSED IN TERMS OF LBS/MMCF.
- G. SOURCE TEST RESULTS SHALL ALSO INCLUDE THE OXYGEN LEVELS IN THE EXHAUST, THE FUEL FLOW RATE, AND THE FLUE GAS FLOW RATE UNDER WHICH THE TEST WAS CONDUCTED.
- H. SOURCE TEST RESULTS SHALL ALSO INCLUDE THE STEAM AND POWER OUTPUT UNDER WHICH THE TEST WAS CONDUCTED.
[RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
8. THE OPERATOR SHALL CONDUCT SOURCE TESTS FOR THE POLLUTANTS IDENTIFIED BELOW:

POLLUTANT	REQUIRED TEST METHOD	AVERAGING TIME	TEST LOCATION
VOC	APPROVED DISTRICT METHOD	1 HOUR	OUTLET OF THE SCR

- A. THE TESTS SHALL BE CONDUCTED AT LEAST ONCE EVERY THREE YEARS. THE FIRST TEST SHALL BE CONDUCTED WITHIN THREE CALENDAR YEARS OF THE TEST REQUIRED IN CONDITION NO. 6.
- B. THE TEST RESULTS SHALL BE SUBMITTED TO THE DISTRICT WITHIN 60 DAYS AFTER THE TEST DATE. THE AQMD SHALL BE NOTIFIED OF THE SCHEDULED TEST DATE AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT.
- C. THE TEST SHALL BE CONDUCTED WHEN THE GAS TURBINE IS OPERATING AS CLOSE AS PRACTICABLE TO 100 PERCENT OF FULL RATED LOAD.
- D. THE TEST SHALL BE CONDUCTED TO DEMONSTRATE COMPLIANCE WITH THE RULE 1303 CONCENTRATION AND/OR MONTHLY EMISSION LIMITS.
[RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
9. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS) TO CONTINUOUSLY MEASURE THE FOLLOWING PARAMETERS:
- CO AND NO_x CONCENTRATIONS IN PPMV.
- A. CONCENTRATIONS SHALL BE CORRECTED TO 15 PERCENT OXYGEN ON A DRY BASIS.



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

- B. THE CEMS SHALL CONVERT THE ACTUAL CO AND NO_x CONCENTRATIONS TO MASS EMISSION RATES (LBS/HR) AND RECORD THE HOURLY EMISSION RATES ON A CONTINUOUS BASIS.
- C. THE CEMS SHALL BE INSTALLED AND OPERATED, IN ACCORDANCE WITH AN APPROVED AQMD RULE 218 AND 218.1 CEMS PLAN APPLICATION. THE OPERATOR SHALL NOT INSTALL THE CEMS PRIOR TO RECEIVING INITIAL APPROVAL FROM AQMD.
- D. THE CEMS SHALL BE INSTALLED AND OPERATED TO MEASURE CO AND NO_x CONCENTRATION OVER A 15 MINUTE AVERAGING TIME PERIOD.
- E. THE CEMS SHALL BE OPERATED AT THE SAME TIME AS THE INITIAL START-UP OF THE TURBINE COGENERATION UNIT. THE CEMS SHALL UNDERGO A SERIES OF CERTIFICATION TESTS WITHIN 90 DAYS OF ITS INSTALLATION IN ACCORDANCE WITH RULE 218(c)(1)(A).
- [RULE 1303(a)(1)-BACT]
10. THE 2 PPMV NO_x EMISSION LIMIT SHALL NOT APPLY DURING STARTUP OR THE COMMISSIONING PERIOD. EACH TURBINE STARTUP EVENT SHALL NOT EXCEED 3 HOURS/EVENT DURING THE COMMISSIONING PERIOD AND 2 HOURS/EVENT DURING NORMAL OPERATIONS. THE NUMBER OF STARTUPS SHALL NOT EXCEED 20 EVENTS/CALENDAR YEAR. THE COMMISSIONING PERIOD SHALL NOT EXCEED 90 CALENDAR DAYS OR 500 OPERATING HOURS FROM THE INITIAL START-UP, WHICHEVER IS EARLIER. THE STARTUP EVENTS DURING THE COMMISSIONING PERIOD SHALL NOT COUNT TOWARDS THE ANNUAL LIMIT OF 20 EVENTS/CALENDAR YEAR. THE OPERATOR SHALL PROVIDE THE AQMD WITH WRITTEN NOTICE OF THE INITIAL STARTUP DATE. WRITTEN RECORDS OF COMMISSIONING AND STARTUP DATES AND DURATION OF EACH OPERATION SHALL BE MAINTAINED AND MADE AVAILABLE UPON REQUEST FROM AQMD. THE 2 PPM NO_x LIMIT SHALL APPLY AT ALL OTHER OPERATING TIMES.
- [RULE 1303(a)(1)-BACT]
11. THE 3 PPMV CO EMISSION LIMIT SHALL NOT APPLY DURING STARTUP OR THE COMMISSIONING PERIOD. EACH TURBINE STARTUP EVENT SHALL NOT EXCEED 3 HOURS/EVENT DURING THE COMMISSIONING PERIOD AND 2 HOURS/EVENT DURING NORMAL OPERATIONS. THE NUMBER OF STARTUPS SHALL NOT EXCEED 20 EVENTS/CALENDAR YEAR. THE COMMISSIONING PERIOD SHALL NOT EXCEED 90 CALENDAR DAYS OR 500 OPERATING HOURS FROM THE INITIAL START-UP, WHICHEVER IS EARLIER. THE STARTUP EVENTS DURING THE COMMISSIONING PERIOD SHALL NOT COUNT TOWARDS THE ANNUAL LIMIT OF 20 EVENTS/CALENDAR YEAR. THE OPERATOR SHALL PROVIDE THE AQMD WITH WRITTEN NOTICE OF THE INITIAL STARTUP DATE. WRITTEN RECORDS OF COMMISSIONING AND STARTUP DATES AND DURATION OF EACH OPERATION SHALL BE MAINTAINED AND MADE AVAILABLE UPON REQUEST FROM AQMD. THE 3 PPM CO LIMIT SHALL APPLY AT ALL OTHER OPERATING TIMES.
- [RULE 1303(a)(1)-BACT]
12. THE 2 PPMV VOC EMISSION LIMIT SHALL NOT APPLY DURING STARTUP OR THE COMMISSIONING PERIOD. EACH TURBINE STARTUP EVENT SHALL NOT EXCEED 3 HOURS/EVENT DURING THE COMMISSIONING PERIOD AND 2 HOURS/EVENT DURING NORMAL OPERATIONS. THE NUMBER OF STARTUPS SHALL NOT EXCEED 20 EVENTS/CALENDAR YEAR.



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

THE COMMISSIONING PERIOD SHALL NOT EXCEED 90 CALENDAR DAYS OR 500 OPERATING HOURS FROM THE INITIAL START-UP, WHICHEVER IS EARLIER. THE STARTUP EVENTS DURING THE COMMISSIONING PERIOD SHALL NOT COUNT TOWARDS THE ANNUAL LIMIT OF 20 EVENTS/CALENDAR YEAR. THE OPERATOR SHALL PROVIDE THE AQMD WITH WRITTEN NOTICE OF THE INITIAL STARTUP DATE. WRITTEN RECORDS OF COMMISSIONING AND STARTUP DATES AND DURATION OF EACH OPERATION SHALL BE MAINTAINED AND MADE AVAILABLE UPON REQUEST FROM AQMD. THE 2 PPM VOC LIMIT SHALL APPLY AT ALL OTHER OPERATING TIMES.

[RULE 1303(a)(1)-BACT]

13. THE OPERATOR SHALL LIMIT EMISSIONS FROM THIS EQUIPMENT AS FOLLOWS:

CONTAMINANT	EMISSIONS LIMIT
CO	1,715 LBS IN ANY CALENDAR MONTH
PM10	1,397 LBS IN ANY CALENDAR MONTH
VOC	1305 LBS IN ANY CALENDAR MONTH
SOx	108 LBS IN ANY CALENDAR MONTH

[RULE 1303(b)(2)-OFFSET]

14. THE 2 PPMV NO_x EMISSION LIMIT SHALL BE AVERAGED OVER 60 MINUTES AT 15 PERCENT OXYGEN, DRY.
[RULE 1303(a)(1)-BACT]
15. THE 3 PPMV CO EMISSION LIMIT SHALL BE AVERAGED OVER 60 MINUTES AT 15 PERCENT OXYGEN, DRY.
[RULE 1303(a)(1)-BACT]
16. THE 2 PPMV VOC EMISSION LIMIT SHALL BE AVERAGED OVER 60 MINUTES AT 15 PERCENT OXYGEN, DRY.
[RULE 1303(a)(1)-BACT]
17. FOR THE PURPOSES OF DETERMINING COMPLIANCE WITH DISTRICT RULE 475, PARTICULATE MATTER EMISSIONS MAY EXCEED THE CONCENTRATION LIMIT OR THE MASS EMISSION LIMIT LISTED IN THE RULE, BUT NOT BOTH LIMITS AT THE SAME TIME.
[RULE 475]
18. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT BY CONDUCTING AN ANNUAL SOURCE TEST AT THE OUTLET OF THE SCR USING AQMD METHOD 5.1.

THE ANNUAL SOURCE TEST FREQUENCY SHALL BE REDUCED TO AT LEAST ONCE EVERY FIVE YEARS IF THREE CONSECUTIVE ANNUAL TESTS SHOW COMPLIANCE WITH EITHER THE CONCENTRATION LIMIT OR THE MASS EMISSION LIMIT. NO TEST SHALL BE REQUIRED IN ANY ONE YEAR FOR WHICH THE EQUIPMENT IS NOT IN OPERATION.

[RULE 3004 – PERIODIC MONITORING]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

19. THE OPERATOR SHALL KEEP RECORDS FROM THE MONITOR AND SOURCE TEST RESULTS REQUIRED BY PERMIT CONDITION NOS. 6, 8, 9 AND 18 FOR A MINIMUM OF FIVE YEARS.
[RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET, RULE 3004 – PERIODIC MONITORING]
20. THE NATURAL GAS FUEL SUPPLIED TO THIS TURBINE SHALL HAVE A SULFUR CONTENT OF NO MORE THAN 150 PPMV SO₂ (0.015% BY VOLUME) ON A DRY BASIS AT 15% O₂ OR 8000 PPMW (0.8% BY WEIGHT) TOTAL SULFUR.
[40 CFR 60 SUBPART GG]
21. A VALID PURCHASE CONTRACT, TARIFF SHEET OR TRANSPORTATION CONTRACT FOR THE NATURAL GAS FUEL WHICH SPECIFIES THE MAXIMUM TOTAL SULFUR CONTENT SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[40 CFR 60 SUBPART GG]

Emissions And Requirements:

22. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NO_x: 199 PPMV, 40CFR 60 SUBPART GG
NO_x: 2 PPMV, RULE 1303(a)(1)-BACT
NO_x: 125 PPM, RULE 476
CO: 3 PPMV, RULE 1303(a)(1)-BACT
CO: 2000 PPMV, RULE 407
VOC: 2 PPMV, RULE 1303(a)(1)-BACT
SO_x: 150 PPMV; 8000 PPMW, 40CFR 60 SUBPART GG
PM: 0.1 GR/SCF, RULE 409
PM: 0.01 GR/SCF; 11LBS/HR, RULE 475, RULE 476



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO OPERATE

**Permit No. F78998
A/N 449144**

Equipment Description:

(located at the Fleet Services)

UNDERGROUND SOIL VAPOR EXTRACTION AND TREATMENT SYSTEM, SOLLECO, MODEL NO. 500, SERIAL NO. C1172, FOR NON-HALOGENATED HYDROCARBON SOIL REMEDIATION SITES ONLY CONSISTING OF:

1. VAPOR EXTRACTION WELLS.
2. EXTRACTION BLOWER, MAXIMUM FLOW RATE 500 SCFM.
3. CATALYTIC/THERMAL OXIDIZER UNIT CONSISTING OF :
 - A. CATALYTIC OXIDIZER, PLATINUM CATALYST ON STAINLESS STEEL, MONOLITHIC TYPE, PROPANE OR NATURAL GAS-FIRED, 1,500,000 BTU PER HOUR MAXIMUM, OR ELECTRICALLY HEATED, 80 KW, WITH AN INTEGRAL HEAT EXCHANGER, A COMBUSTION BLOWER, 125 SCFM MAXIMUM, AND AN AUTOMATIC TEMPERATURE CONTROLLER.
 - B. THERMAL OXIDIZER, PROPANE OR NATURAL GAS-FIRED, WITH AN AUTOMATIC TEMPERATURE CONTROL SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. UPON COMPLETION, ANY VAPOR EXTRACTION WELLS AND DUCTS SHALL BE CAPPED TO PREVENT VAPORS FROM VENTING TO THE ATMOSPHERE. VAPORS SHALL NOT BE EXTRACTED FROM THE SOIL, UNLESS THEY ARE VENTED TO THE VAPOR CONTROL SYSTEM, WITH NO DETECTABLE LEAK BETWEEN THE OUTLET OF THE BLOWER AND THE OUTLET OF THE VAPOR CONTROL SYSTEM.
[RULE 1166]
4. AN IDENTIFICATION TAG OR NAMEPLATE SHALL BE DISPLAYED ON THE EQUIPMENT TO SHOW MANUFACTURER, MODEL NO., SERIAL NO., FLOW RATING, AND VOLUME OF CATALYST. THE TAG(S) AND PLATE(S) SHALL BE ISSUED BY THE MANUFACTURER AND SHALL BE AFFIXED TO THE EQUIPMENT IN A PERMANENT AND CONSPICUOUS POSITION.



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

[RULE 1166]

5. THIS EQUIPMENT SHALL ONLY BE USED TO EXTRACT AND TREAT NON-CHLORINATED PETROLEUM HYDROCARBON VAPORS. THIS SHALL BE DEMONSTRATED BY AN ONSITE SOIL CHARACTERIZATION ANALYSIS REPORT.

[RULE 1166]

6. UPON THE FIFTH DAY AFTER PLACEMENT OF THIS EQUIPMENT INTO OPERATION AT A NEW SITE, THE DISTRICT SHALL BE NOTIFIED VIA TELEPHONE AT 1-877-810-6995 OF THE EXACT NATURE OF THE PROJECT AS FOLLOWS:

- A. THE PERMIT NUMBER OF THE PORTABLE EQUIPMENT.
- B. THE NAME AND PHONE NUMBER OF A CONTACT PERSON.
- C. THE LOCATION WHERE THE PORTABLE EQUIPMENT WILL BE OPERATED.
- D. THE ESTIMATED TIME THE PORTABLE EQUIPMENT WILL BE LOCATED AT THE SITE.
- E. DESCRIPTION OF THE PROJECT.
- F. IF LESS THAN ¼ MILE, THE DISTANCE TO THE NEAREST SENSITIVE RECEPTOR. (SENSITIVE RECEPTOR IS DEFINED AS LONG-TERM HEALTH CARE FACILITIES, REHABILITATION CENTERS, CONVALESCENT CENTERS, RETIREMENT HOMES, RESIDENCES, SCHOOLS, PLAYGROUNDS, CHILD CARE CENTERS, AND ATHLETIC FACILITIES).

IN CASE OF A VENT TEST, THE DISTRICT SHALL BE NOTIFIED 24 HOURS PRIOR TO PLACING THE EQUIPMENT INTO OPERATION.

[RULE 1166]

7. THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 12 CONSECUTIVE MONTHS AT ANY ONE FACILITY WITHIN THE SCAQMD. ANY EQUIPMENT THAT REPLACES THIS EQUIPMENT AT THIS SITE AND IS INTENDED TO PERFORM THE SAME FUNCTION AS THE EQUIPMENT BEING REPLACED SHALL BE INCLUDED IN CALCULATING THE RESIDENCY TIME PERIOD.

[RULE 1166]

8. A FLOW INDICATOR SHALL BE INSTALLED AND MAINTAINED AT ALL INLET STREAMS TO THE VAPOR CONTROL SYSTEM TO INDICATE THE TOTAL AIR FLOW RATE IN STANDARD CUBIC FEET PER MINUTE (SCFM). THE TOTAL FLOW RATE SHALL NOT EXCEED 625 SCFM IN EITHER THERMAL OR CATALYTIC MODE. IN CASE A PRESSURE SENSOR DEVICE IS USED IN PLACE OF THE FLOW INDICATOR, A CONVERSION CHART SHALL BE AVAILABLE TO INDICATE THE CORRESPONDENT FLOW RATE, IN SCFM, TO THE PRESSURE READING.

[RULE 1166, RULE 3004(a)(4)]

9. THERMAL OXIDIZER

- A. A TEMPERATURE MEASUREMENT AND RECORDING DEVICE WITH AN ACCURACY OF PLUS OR MINUS 20 DEGREES FAHRENHEIT SHALL BE INSTALLED AND MAINTAINED AT THE OUTLET OF THE COMBUSTION CHAMBER.
- B. WHENEVER THE VAPOR CONTROL SYSTEM IS OPERATING IN THE THERMAL MODE, THE TEMPERATURE AT THE OUTLET OF THE COMBUSTION CHAMBER SHALL NOT BE LESS THAN 1400 DEGREES FAHRENHEIT.

[RULE 1166, RULE 3004(a)(4)]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

10. CATALYTIC OXIDIZER

- A. A TEMPERATURE MEASUREMENT AND RECORDING DEVICE WITH AN ACCURACY OF PLUS OR MINUS 20 DEGREES FAHRENHEIT SHALL BE INSTALLED AND MAINTAINED AT THE INLET OF THE FIRST STAGE CATALYST BED.
- B. WHENEVER THE VAPOR CONTROL SYSTEM IS OPERATING IN THE CATALYTIC MODE, THE TEMPERATURE AT THE INLET OF THE FIRST STAGE CATALYST BED SHALL NOT BE LESS THAN 600 DEGREES FAHRENHEIT.

[RULE 1166, RULE 3004(a)(4)]

11. VOLATILE ORGANIC COMPOUND (VOC) CONCENTRATION SHALL BE MEASURED AT THE OUTLET OF THE VAPOR CONTROL SYSTEM AT LEAST ONCE EVERY SEVEN OPERATING DAYS BY USING A FLAME IONIZATION DETECTOR OR A DISTRICT APPROVED ORGANIC VAPOR ANALYZER (OVA) CALIBRATED IN PARTS PER MILLION BY VOLUME (PPMV) AS HEXANE (IF ANOTHER CALIBRATING AGENT WAS USED, IT SHALL BE CORRELATED TO AND EXPRESSED AS HEXANE).

[RULE 1166, RULE 3004(a)(4)]

12. VOC CONCENTRATION AT THE OUTLET OF THE VAPOR CONTROL SYSTEM SHALL NOT EXCEED 75 PPMV, MEASURED AS HEXANE.

[RULE 1166]

13. WITHIN ONE WEEK OF START-UP AND ONCE A MONTH THEREAFTER, AT EACH LOCATION, GRAB SAMPLES OF THE EXHAUST SHALL BE TAKEN AND ANALYZED FOR BENZENE CONCENTRATION. BENZENE CONCENTRATION IN THE EXHAUST OF THE VAPOR CONTROL SYSTEM SHALL NOT EXCEED 0.15 PPM. RESULTS OF THE ANALYSES SHALL BE RECORDED AND MAINTAINED.

[RULE 1166, RULE 3004(a)(4)]

14. EQUIPMENT SHUTDOWN INTERLOCKS SHALL BE PROVIDED FOR LOW OPERATING TEMPERATURES OF THE THERMAL AND CATALYTIC OXIDIZERS.

[RULE 1166]

15. THE EXIT TO THE EXHAUST STACK SHALL HAVE A MINIMUM HEIGHT OF 13 FEET MEASURED FROM GRADE.

[RULE 1166]

16. RECORDS SHALL MAINTAINED TO PROVE COMPLIANCE WITH THESE CONDITIONS. RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.

[RULE 1166]

Emissions And Requirements:

17. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO CONSTRUCT/OPERATE

**Permit No. F90012
A/N 463910**

Equipment Description:

(located at the Student Center)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 4BTA3.9-G5, TURBOCHARGED, AFTERCOOLED, 4 CYLINDERS, FOUR CYCLE, 99 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

- A. EMERGENCY USE HOURS OF OPERATION
- B. MAINTENANCE AND TESTING HOURS
- C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

PERMIT TO CONSTRUCT/OPERATE

**Permit No. F90013
A/N 464442**

Equipment Description:

(located at Bio Sci 3)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QST30-G5, TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, FOUR CYCLE, 1490 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME..
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

- A. EMERGENCY USE HOURS OF OPERATION
- B. MAINTENANCE AND TESTING HOURS
- C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

PERMIT TO CONSTRUCT/OPERATE

Permit No. F96301
A/N 475432

Equipment Description:

(located at the Anteater Recreation Center))

INTERNAL COMBUSTION ENGINE, JOHN DEERE, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 4045HF285J, TURBOCHARGED, AFTERCOOLED, FOUR CYLINDERS, 4-CYCLE, 126 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

- A. EMERGENCY USE HOURS OF OPERATION
- B. MAINTENANCE AND TESTING HOURS
- C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, > 400,000 BTU/HR BUT \leq 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409
NOx: 30 PPMV, RULE 1146.2
CO: 400 PPMV, RULE 1146.2
CO: 2000 PPMV, RULE 407



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERANT RECOVERY AND/OR RECYCLING UNITS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT:	RULE 1415
REFRIGERANT:	40CFR 82 SUBPART F
REFRIGERANT:	40CFR 82 SUBPARTG



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERANT RECOVERY AND/OR RECYCLING UNITS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT:	RULE 1411
REFRIGERANT:	40CFR 82 SUBPART F
REFRIGERANT:	40CFR 82 SUBPARTG



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, CHARBROILER.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - A. DATE
 - B. DAILY OPERATING HOURS
 - C. DAILY AMOUNT OF MEAT COOKED (OR CASHIER'S RECEIPTS WHICH SHOW THE QUANTITY OF CHARBROILER PRODUCTS SOLD EACH DAY)[RULE 3004 (a)(4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: 0.1 GR/SCF, RULE 409
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under Section 129(e) of the Clean Air Act, this permit shall expire five years from the date that the initial Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:

(A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

SECTION K: TITLE V Administration

- (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
- (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

- 8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
 - (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]
- 9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
- 10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

SECTION K: TITLE V Administration

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]
14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
 - (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

SECTION K: TITLE V Administration

commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

SECTION K: TITLE V Administration

EMERGENCY PROVISIONS

17. An emergency¹ constitutes an affirmative defense to an action brought for non-compliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 - Breakdown Provisions, or subdivision (i) of Rule 2004 - Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

SECTION K: TITLE V Administration

RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:
- (A) Breakdowns shall be reported as required by Rule 430 - Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.
 - (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.



FACILITY PERMIT TO OPERATE UNIV. CAL IRVINE (NSR USE ONLY)

SECTION K: TITLE V Administration

- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
 - (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;
 - (B) The compliance status during the reporting period;
 - (C) Whether compliance was continuous or intermittent;
 - (D) The method(s) used to determine compliance over the reporting period and currently, and
 - (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn: Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

SECTION K: TITLE V Administration

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the Title V application file. [3004(a)(4)]



**FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)**

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations:

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	7-13-2007	Non federally enforceable
RULE 1136	6-14-1996	Federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146.2	1-7-2005	Non federally enforceable
RULE 1146.2	1-9-1998	Federally enforceable
RULE 1166	5-11-2001	Non federally enforceable
RULE 1166	7-14-1995	Federally enforceable
RULE 1170	5-6-1988	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	7-14-2006	Non federally enforceable
RULE 118	12-7-1995	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)-Modeling	12-6-2002	Non federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	12-7-1990	Non federally enforceable
RULE 1401	3-17-2000	Non federally enforceable
RULE 1401	3-4-2005	Non federally enforceable
RULE 1401	5-2-2003	Non federally enforceable
RULE 1401	5-3-2002	Non federally enforceable
RULE 1401	8-13-1999	Non federally enforceable
RULE 1401	8-18-2000	Non federally enforceable
RULE 1411	3-1-1991	Non federally enforceable
RULE 1415	10-14-1994	Non federally enforceable
RULE 1470	6-1-2007	Non federally enforceable



**FACILITY PERMIT TO OPERATE
UNIV/CAL IRVINE (NSR USE ONLY)**

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 204	10-8-1993	Federally enforceable
RULE 206	10-8-1993	Federally enforceable
RULE 212	11-14-1997	Non federally enforceable
RULE 212	12-7-1995	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 219	6-1-2007	Non federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 2202	2-6-2004	Non federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3003	11-14-1997	Federally enforceable
RULE 3003	3-16-2001	Non federally enforceable
RULE 3004	12-12-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3005	3-16-2001	Non federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 304	6-9-2006	Non federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 461	6-3-2005	Federally enforceable
RULE 475	10-8-1976	Federally enforceable
RULE 475	8-7-1978	Non federally enforceable
RULE 476	10-8-1976	Federally enforceable
40CFR 60 Subpart GG	2-24-2006	Federally enforceable
RULE 701	6-13-1997	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 11-8-1996]

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

**Grams of VOC Per Liter of Coating,
Less Water And Less Exempt Compounds**

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior	350	450		350			
Coatings							
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250				100		50
Graphic Arts (Sign) Coatings	500						
Industrial Maintenance							



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 11-8-1996]

Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550		275	
Pre-Treatment Wash Primers	780					
Primers, Sealers, and	350					
Undercoaters						
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards



FACILITY PERMIT TO OPERATE

UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS **[RULE 1113 11-8-1996]**

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120



FACILITY PERMIT TO OPERATE UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 7-13-2007]

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings, except anti-graffiti coatings, for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.



FACILITY PERMIT TO OPERATE **UNIV CAL IRVINE (NSR USE ONLY)**

APPENDIX B: RULE EMISSION LIMITS **[RULE 1113 7-13-2007]**

TABLE OF STANDARDS **VOC LIMITS**

**Grams of VOC Per Liter of Coating,
Less Water and Less Exempt Compounds**

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		
Nonflat High Gloss	250		150				50	



FACILITY PERMIT TO OPERATE

UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 7-13-2007]

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings	300		250		50			
Roof Coatings, Aluminum	500				100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac								
Clear	730							
Pigmented	550							
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing	400					100		
Concrete/Masonry Sealers								
Wood Preservatives								
Below-Ground	350							
Other	350							

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

** Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

*** The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.



FACILITY PERMIT TO OPERATE

UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS **[RULE 1113 7-13-2007]**

TABLE OF STANDARDS (cont.) **VOC LIMITS**

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1136 6-14-1996]

Except as otherwise provided in Rule 1136

- (a) The operator shall not apply any coating to a wood product which has a VOC content, including any VOC-containing material added to the original coating supplied by the manufacturer, which exceeds the applicable limit specified below:

<u>COATING</u>	VOC LIMITS Grams Per Liter (lb/gal) of Coating, [lbs VOC/lb of solids], <u>Less Water and Less Exempt Compounds</u>		
	<u>Current Limit</u>		<u>On and After</u> <u>7/1/2005</u>
	<u>I</u>	<u>or</u> <u>II</u>	
Clear Sealers	550 (4.6) [1.39]	680 (5.7) [3.36]	275 (2.3) [0.36]
Clear Topcoat	550 (4.6) [1.37]	275 (2.3) [0.35]	275 (2.3) [0.35]
Pigmented Primers, Sealers & Undercoats	550 (4.6) [1.06]	600 (5.0) [1.08]	275 (2.3) [0.21]
Pigmented Topcoats	550 (4.6) [1.10]	275 (2.3) [0.25]	275 (2.3) [0.25]

The operator shall use coatings on a wood product that comply with either all VOC limits in column I or all VOC limits in column II. The operator that applies a primer, sealer or undercoat, but not a topcoat, to a wood product, shall be subject to column I for that wood product.

- (2) Notwithstanding the requirements of clause (a)(1), an operator that applies a topcoat and a primer, sealer or undercoat to a shutter may, until July 1, 2005, choose to comply with the VOC limits specified below for that shutter:

VOC LIMITS Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids], <u>Less Water and Less Exempt Compounds</u>	
<u>COATING</u>	
Clear Sealers	275 (2.3) [0.36]
Clear Topcoat	680 (5.7) [2.99]
Pigmented Primers, Sealers & Undercoats	275 (2.3) [0.33]
Pigmented Topcoats	600 (5.0) [1.38]



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1136 6-14-1996]

(3)

VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

<u>COATING</u>	<u>Current Limit</u>	<u>On and After</u>
		<u>7/1/2005</u>
Barrier Coat - Plastic Components	760 (6.3) [3.9]	275 (2.3) [0.28]
Composite Wood Edge Filler	550 (4.6) [1.15]	275 (2.3) [0.31]
Extreme Performance Coatings	420 (3.5) [0.51]	275 (2.3) [0.33]
Fillers	500 (4.2) [0.66]	275 (2.3) [0.18]
High-Solid Stains	550 (4.6) [1.23]	350 (2.9) [0.42]
Inks	500 (4.2) [0.96]	500 (4.2) [0.96]
Mold-Seal Coatings	750 (6.3) [4.2]	750 (6.3) [4.2]
Multi-Colored Coatings	685 (5.7) [2.6]	275 (2.3) [0.33]

VOC LIMITS

Grams Per Liter (lb/gal) of Material

<u>COATING</u>	<u>Current Limit</u>	<u>On and After</u>
		<u>7/1/2005</u>
Low-Solids Barrier Coat - Plastic Components	760 (6.3)	120 (1.0)
Low-Solid Stains, Toners, and Washcoats	480 (4.0)	120 (1.0)

Any coating subject to this rule that meets any of the three VOC limit formats (grams per liter, lb/gal, or lbs VOC/lb of solids) is in compliance with this subparagraph.

- (4) The VOC limit for japan coatings is 700 grams per liter of coatings, less water and exempt compounds, as applied.
- (b) A person shall not use a stripper on wood products unless:
- (1) it contains less than 350 grams of VOC per liter of material; or
 - (2) the VOC composite vapor pressure is 2 mm Hg (0.04 psia) or less at 20°C (68°F).



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-7-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-7-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-7-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)



FACILITY PERMIT TO OPERATE

UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 7-14-2006]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	CURRENT LIMITS*	EFFECTIVE 1/1/2008
SOLVENT CLEANING ACTIVITY	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 7-14-2006]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components		
(I) Newsprint	100 (0.83)	



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 7-14-2006]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(II) Other Substrates	500 (4.2)	100 (0.83)
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	500 (4.2)	100 (0.83)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

* The specified limits remain in effect unless revised limits are listed in subsequent columns.



FACILITY PERMIT TO OPERATE
UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS
[RULE 404 2-7-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a).

Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402



FACILITY PERMIT TO OPERATE

UNIV CAL IRVINE (NSR USE ONLY)

APPENDIX B: RULE EMISSION LIMITS [RULE 404 2-7-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100